

# IoT Gateway (Model: LM Gateway414-IoT) Data Sheet V2.3.1

#### PRODUCT INTRODUCTION

LM Gateway414-IoT provides 4 RS-485/323 serial ports and 2 10/100 Mbps Ethernet port.It provides complete industrial protocols support including Modbus, BACnet, OPCUA, DLT645, CJ188, etc, provides external data as Modbus RTU/TCP, Bacnet server. The gateway and cloud platform use the instant messaging protocol MQTT to transmit data. The gateway can be used as an MQTT client to connect to Alibaba Cloud, Amazon Cloud,etc. The data points of the gateway are pushed to the cloud through the mechanism of subscription and published, and the cloud can read and write to the collected device through the gateway, which supports disconnected storage.



## HARDWARE SPECIFICATION

LM Gateway414 Hardware parameters:			
CPU	4 Core A9,clocked at 1.4GHz		
RAM	512MB DDR3 high performance memory		
Nand Flash	MLC eMMC ,Onboard as 4GByte eMMC		
Serial Port	4 fully isolated RS485 interfaces		
Network	2 100M/10M Ethernet interface		
Port			
Power	DC9V $\sim$ 36V, Anti-reverse connection,		
Supply	lightning resistance, overcurrent,etc.		
WIFI	USB WLAN card optional		
<b>Total Weight</b>	230g		
Enclosure	IP51		
rating			
Installation	140mm×112mm×35mm(L×W×H)		
size			
Mechanical	DIN rail card slot fixing		
installation			
LM Gateway414 Environmental parameters:			
Power	The biggest power consumption ≤ 5W,≤3W		
consumption			
Temperature	-40∼80℃		
and	20~90% non-condensing		
Humidity			

#### **INTERFACE DEFINITION**

SIGNAL	DESCRIPTION
Vin+	Positive power supply
Vin-	Negative power supply
Е	Safety ground

- 2. Network port
- 10/100M high speed adaptive network card;
- Two-stage lightning protection and anti-static protection, can resist 2KV lightning;
- Unique MAC address.

LAN DEFAULT IP		SUBNET MASK
Eth0	192.168.1.230	255.255.255.0
Eth1	192.168.0.230	255.255.255.0

- Eth0 can be used as a LAN port or a WAN port to support access to the Internet
- Eth1 is a LAN port and can only be used for LAN;
- 3. CON

3. CON		
PIN	SIGNAL	DESCRIPTION
1	COM1-A	RS485-1 Positive signal
2	COM1-B	RS485-1 Negative signal
3	COM2-A	RS485-2 Positive signal
4	сом2-в	RS485-2 Negative signal
5	сомз-а	RS485-3 Positive signal
6	сомз-в	RS485-3 Negative signal
8	COM3-GND	RS485-3 Signal ground
9	сомз-тх	RS232-3 Signal sender
10	COM3-RX	RS232-3 Signal receiver
11	COM4-A	RS485-4 Positive signal
12	СОМ4-В	RS485-4 Negative signal
13	COM4-GND	RS485-4 Signal ground
14	COM4-TX	RS232-4 Signal sender
15	COM4-RX	RS232-4 Signal receiver

### RS485:

- Fully isolated RS485 interface with three levels of protection;
- Supports the highest level of 4KV protection for the 10/700uS test in the GB/T 17626.5-2008 standard;
- ±15kV human body discharge mode;
- ±15kV IEC1000-4-2 air gap discharge;
- Communication parameters can be configured, default communication parameters: 9600, 8-1-N.

#### 4 . LEDx-Lightings

PIN	SIGNAL	DESCRIPTION
1	POWER	Power indication
2	RUN	System operation indication
3	COM1	Serial port 1 send and receive instructions, "green" sends, "yellow" receives
4	COM2	Serial port 2 send and receive instructions, "green" sends, "yellow" receives
5 COM3		Serial port 3 send and receive instructions, "green" sends, "yellow" receives

6	COM4	Serial port 4 send and receive instructions,
		"green" sends, "yellow" receives

#### **DATA SERVICE**

- The gateway provide external data as a Modbus RTU and Modbus TCP server. It supports 4 functional areas(0x, 1x, 3x, 4x) & various types of data(int16, int32, float32,etc.)
- ♣ Provide data to the host computer as an OPC UA server。
- The gateway can connect to Alibaba Cloud, Amazon Cloud, etc as an MQTT client. The data points of the gateway are pushed to the cloud through the mechanism of subscription and published, we can read and write to the collected device in the cloud through the gateway
- The gateway provides an http server, which supports two common methods(GET and POST). Users can retrieve real-time data and stored historical data of the gateway through the http server interface
- The gateway push the gateway's data points to specific topics as a kafka client side
- The gateway can be used as a remote data client side port to provide services and support data to be written directly to the remote database
- ♣ Provide data externally as BACnet IP,Bacnet MS/TP server.Support AI, AO, AV, BI, BO, BV, MSI, MSO, MSV,etc and data units configuration. Support Who-Is and I-Am services, COV subscription, read&write and other services.

### **DATA OPERATION**

Support arithmetic and function operations, logical judgments, Boolean operations.

## REMOTE DATA STORAGE

The gateway connects to the database server as the database client, and writing data directly to the remote database. Currently supported database types are: mysql

### IoT

With the MQTT protocol, the gateway can communicate with the cloud server. Support Alibaba Cloud, Amazon Cloud and other private cloud servers.

#### ALARM AND EVENTS

The Alarms and Events page allows the user to set the trigger condition for the event, trigger the event when the condition is met, and perform the event release when the state transitions from the satisfied condition to the unsatisfied condition.




## **MISSION PLAN**

The user establishes a mission plan that specifies the values for multiple points for the day of the week and time period. Please calibrate the gateway time before using the mission planning function.

## **JavaScript EDITING**

JavaScript script editor built-in function, user can customize logic control by editing script language.

## -----Diagram-----



## **CONFIGURING THE GATEWAY**

#### 1.Power the gateway;

2.Connect the LM Gateway101 data collection gateway to the computer or switch using a crossover cable; (PS. the gateway and the computer are in the same network segment);

3.Use the tool software to configure the data acquisition gateway. For the operation, see the configuration manual of the configuration tool.

	Data	C : ID .	No. 18
	collection driver	Serial Port	Network Port
	Modbus	Modbus RTU	Modbus TCP
		ModbusAscii	Modbus RTU over TCP
	DLT645	DLT645-1997	
Instrument		DLT645-2007	DLT645_over_TCP
ation		DLT645.98	
	CJ188	CJ188	1
	Maria	MBus_EnergyMeter	1
	Mbus	MBus_EN1434	_ /
	NA:tarrhiah:	Mitsubishi Fx3U	MC_Qna-3EBinary
	Mitsubishi	Mitsubishi Fx485	MC_Qna-1EBinary
			Siemens S7-200 Network
			Siemens S7-300 Network
	Siemens	Siemens S7-200 PPI	Siemens S7-400 Network
			Siemens S7-1200 Network
PLC			Siemens S7-1500 Network
PLC			FetchWrite
	AB	1	AB NET
	Omron	HOSTLINK-FINS	OMRON_FINS
		HOSTLINK-CMODE	
	Panasonic	Mewtocol	1
	Yokogawa	1	Yokogawa PLC
	FUJI	1	FUJI_SPH_NET
Eco protection	212	HJ 212 serial	HJ 212 net
D:Lalias as	DAC	DAC: at MC/TD	BACnet IP
Building	BACnet	BACnet MS/TP	KNX
		/	OPC UA
Industrial	OPC		OPC DA
			OPC XML DA
Substation	IEC	1	IEC104
CNC	FANUC		FANUC



